



STANDARD CURB AND GUTTER

TYPICAL SECTION

1" = 1'

NOTES

- ① ALL CONCRETE SHALL BE K.D.O.T. CLASS "A" CONCRETE. EXPANSION JOINT ARE REQUIRED AT A MINIMUM OF 50' INTERVALS. CONTRACTION JOINTS ARE REQUIRED OF A MINIMUM OF 10' INTERVALS.
- ② 2" MINIMUM LIFT OF COMPACTED DENSE GRADE AGGREGATE
- ③ EXPANSION JOINT SHALL BE USED WHEN SIDEWALK/DRIVE ENTRANCE IS FLUSH TO BACK OF CURB.



CITY OF BOWLING GREEN  
PUBLIC WORKS  
PLANNING AND DESIGN

STANDARD DRAWING  
CURB & GUTTER

J:\DWG\DETAIL\CURESTD.DWG

SHEET 1 OF 1

JOB NO. 00-0000 SCALE 1" = 1' DATE 12/29/99